Notice of Allowability	10/664,765	XIA ET AL.	
	Examiner		QV)
	Robert J. Popovics	1724	
The MAILING DATE of this communication appears on the cover sheet with the correspondence address All claims being allowable, PROSECUTION ON THE MERITS IS (OR REMAINS) CLOSED in this application. If not included herewith (or previously mailed), a Notice of Allowance (PTOL-85) or other appropriate communication will be mailed in due course. THIS NOTICE OF ALLOWABILITY IS NOT A GRANT OF PATENT RIGHTS. This application is subject to withdrawal from issue at the initiative of the Office or upon petition by the applicant. See 37 CFR 1.313 and MPEP 1308.			
1. 🔀 This communication is responsive to <u>2/6/04</u> .			
2. X The allowed claim(s) is/are <u>1-28 and 47</u> .			
3. 🔀 The drawings filed on <u>17 September 2003</u> are accepted by the Examiner.			
4.			
<ul> <li>Attachment(s)</li> <li>1.  Notice of References Cited (PTO-892)</li> <li>2.  Notice of Draftperson's Patent Drawing Review (PTO-948)</li> <li>3.  Information Disclosure Statements (PTO-1449 or PTO/SB/0 Paper No./Mail Date 9/17/03</li> <li>4.  Examiner's Comment Regarding Requirement for Deposit of Biological Material</li> </ul>	5. Notice of Informal F 6. Interview Summary Paper No./Mail Da 7. Examiner's Amenda 8. Examiner's Statema 9. Other	(PTO-413), te ment/Comment	·

Application No.

-

Applicant(s)

Application/Control Number: 10/664,765

**Art Unit: 1724** 

## **REASONS FOR ALLOWANCE**

The following is an examiner's statement of reasons for allowance: The prior art of record fails to teach or suggest a filter including a washbox, an airlifting tube having an expulsion end within the washbox and an intake at a lower end, a central pipe, an effluent riser pipe, an effluent chamber, at least one screen cartridge in communication with a lower portion of the effluent chamber, the screen cartridge oriented in a generally angular downward direction, a reject outlet pipe communicating the washbox with a reject box and an effluent collector communicating the effluent chamber with a location outside of the liquid filtering apparatus.

Any comments considered necessary by applicant must be submitted no later than the payment of the issue fee and, to avoid processing delays, should preferably accompany the issue fee. Such submissions should be clearly labeled "Comments on Statement of Reasons for Allowance."

Any inquiry concerning this communication or earlier communications from the examiner should be directed to Robert J. Popovics whose telephone number is (571) 272-1164. If attempts to reach the examiner by telephone are unsuccessful, the examiner's supervisor, Blaine Copenheaver can be reached on (571) 272-1156. The fax phone number for the organization where this application or proceeding is assigned is 703-872-9306.

Application/Control Number: 10/664,765

**Art Unit: 1724** 

Information regarding the status of an application may be obtained from the Patent Application Information Retrieval (PAIR) system. Status information for published applications may be obtained from either Private PAIR or Public PAIR. Status information for unpublished applications is available through Private PAIR only. For more information about the PAIR system, see http://pair-direct.uspto.gov. Should you have questions on access to the Private PAIR system, contact the Electronic Business Center (EBC) at 866-217-9197 (toll-free).

Robert James Popovics Primary Examiner

Art Unit 1724

March 17, 2004